

Intertek ETL SEMKO

VERIFICATION

of conformity with European Directives

Order No. JSH0405589
Type of equipment Split Type Air Conditioner
Applicant /Manufacturer Shanghai Shining Air-conditioner Manufacture Co.,Ltd.
No. 188, Qijin Road, Jinhui Town, Fengxian District
Shanghai 201404, P.R.China
Manufacturing site Shanghai Shining Air-conditioner Manufacture Co.,Ltd.
No. 188, Qijin Road, Jinhui Town, Fengxian District
Shanghai 201404, P.R.China
Type designation KFR-70DW; KF-70DW
Technical data KFR-70DW: 230V~, 50Hz, Cooling rated input: 2900W/13A, Heating
rated input:2800W/12.5A, R407C/2150g, Class I, IP 24(outdoor unit),
Compressor model: PG440X3CS-4xy1 (Mezhi)
KF-70DW: 230V~, 50Hz, Cooling rated input: 2900W/13A,
R407C/2150g, Class I, IP 24(outdoor unit), Compressor model:
PG440X3CS-4xy1 (Mezhi)

The submitted sample of the above equipment has been tested for CE marking according to the following European Directives:

- the Low Voltage Directive 73/23/EEC amended by 93/68/EEC

Standard(s) used for showing compliance with the essential requirements in the specified directive(s):


Standard(s)	Test report(s)	Issued by	Date(s)
EN 60335-2-40:2003	Ref. No.	Intertek Testing	2004-07-06
EN 60335-1:2002	JSH0405589-004	Services Shanghai Limited	

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified EU Directive(s).

After preparation of the necessary technical documentation as well as the conformity declaration and having the required quality measures in place the CE marking as shown below may be affixed by the manufacturer on the equipment provided that other relevant directives that shall be covered by the CE marking also are complied with.

NOTE: This verification is part of the full test report and should be read in conjunction with it.

Shanghai, July 7, 2004


James Lu
HA Manager



Intertek, ETL SEMKO
Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Tel: 86 21 6495 6565 Fax: 86 21 6495 6263 www.intertek-etlsemko.com

Intertek ETL SEMKO

VERIFICATION

of conformity with European Directives

Order No. JSH0405589
Type of equipment Split Type Air Conditioner
Applicant /Manufacturer Shanghai Shining Air-conditioner Manufacture Co.,Ltd.
No. 188, Qijin Road, Jinhui Town, Fengxian District
Shanghai 201404, P.R.China
Manufacturing site Shanghai Shining Air-conditioner Manufacture Co.,Ltd.
No. 188, Qijin Road, Jinhui Town, Fengxian District
Shanghai 201404, P.R.China
Type designation KFR-120DW; KF-120DW; KFR-100DW; KF-100DW; KFR-140DW;
KF-140DW
Technical data See attachment.

The submitted sample of the above equipment has been tested for CE marking according to the following European Directives:

- the Low Voltage Directive 73/23/EEC amended by 93/68/EEC

Standard(s) used for showing compliance with the essential requirements in the specified directive(s):


Standard(s)	Test report(s)	Issued by	Date(s)
EN 60335-2-40:2003	Ref. No.	Intertek Testing	2004-07-06
EN 60335-1:2002	JSH0405589-006	Services Shanghai Limited	

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified EU Directive(s).

After preparation of the necessary technical documentation as well as the conformity declaration and having the required quality measures in place the CE marking as shown below may be affixed by the manufacturer on the equipment provided that other relevant directives that shall be covered by the CE marking also are complied with.

NOTE: This verification is part of the full test report and should be read in conjunction with it.

Shanghai, July 7, 2004



James Lu
HA Manager



Intertek, ETL SEMKO
Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Tel: 86 21 6495 6565 Fax: 86 21 6495 6263 www.intertek-etlsemko.com

Intertek ETL SEMKO

KFR-120DW: 400V~3N, 50Hz, Cooling rated input: 4800W/8.5A, Heating rated input:4500W/8A, R407C/3200g, Class I, IP 24(outdoor unit), Compressor model: C-SBN373H8A (Sanyo)

KF-120DW: 400V~3N, 50Hz, Cooling rated input: 4800W/8.5A, R407C/3200g, Class I, IP 24(outdoor unit), Compressor model: C-SBN373H8A (Sanyo)

KFR-100DW: 400V~3N, 50Hz, Cooling rated input: 4800W/8.5A, Heating rated input:4500W/8A, R407C/3200g, Class I, IP 24(outdoor unit), Compressor model: C-SBN373H8A (Sanyo)

KF-100DW: 400V~3N, 50Hz, Cooling rated input: 4800W/8.5A, R407C/3200g, Class I, IP 24(outdoor unit), Compressor model: C-SBN373H8A (Sanyo)

KFR-140DW: 400V~3N, 50Hz, Cooling rated input: 4800W/8.5A, Heating rated input:4500W/8A, R407C/3200g, Class I, IP 24(outdoor unit), Compressor model: C-SBN373H8A (Sanyo)

KF-140DW: 400V~3N, 50Hz, Cooling rated input: 4800W/8.5A, R407C/3200g, Class I, IP 24(outdoor unit), Compressor model: C-SBN373H8A (Sanyo)



Intertek, ETL SEMKO

Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Tel: 86 21 6495 6565 Fax: 86 21 6495 6263 www.intertek-etlsemko.com

